



Monroe Energy, LLC
Trainer Refinery
4101 Post Road
Trainer, PA 19061
(610) 364-8000

January 28, 2013

Via Fedex – 8001 2756 5723

Mr. James Rebarchak
Program Manager, Air Quality Program
PA Department of Environmental Protection
Southeast Regional Office
2 East Main Street
Norristown, PA 19401

**RE: Monroe Energy, LLC – Trainer Refinery
40 CFR 60, Subpart QQQ Semi-Annual Report
Reporting Period: July 1 – December 31, 2012
Title V Operating Permit No. 23-00003**

RECEIVED
JAN 30 2013
3AP20

Mr. Rebarchak:

In accordance with 40 CFR Part 60, Subpart QQQ – Standards of Performance for VOC Emissions from Petroleum Refinery Wastewater Systems, the Monroe Energy - Trainer Refinery respectfully submits this Semi-Annual Report for the July 1, 2012 through December 31, 2012 reporting period.

Oil Water Separators

All required visual inspections and monitoring activities were completed during the reporting period. No leaks were observed during the visual inspections and Method 21 monitoring activities performed on the following equipment:

- North and South Bays of the API.
- Fixed inlet and outlet covers on the API separator.
- Regulated carbon canisters.
- Regulated slop oil tanks.

Drains

All required monthly inspections of regulated drains were completed during the reporting period. The results of the monthly inspections are summarized as follows:

- July - Water level was raised in drains 1-3 and 1-4, and a plug was tightened on drain 2-4.
- August - No discrepancies were observed.
- September - No discrepancies were observed.
- October - No discrepancies were observed.
- November - No discrepancies were observed.

- December - Water level was raised in drains 4-14 and 6-38, and plugs were tightened on drains 2-1, 2-2, 2-3, and 2-4.

Junction Boxes

All required semi-annual visual inspections of regulated junction boxes and unburied sewer lines were completed during this reporting period. No deviations were identified.

Please contact Liddie Clark at (610) 364-8090 or Liddie.Clark@monroe-energy.com if you have any questions or comments regarding this report.

I certify that, based on information and belief formed after reasonable inquiry, the statements and information contained in this form are true, accurate, and complete.

Sincerely,



Jeffery K. Warmann
CEO and President

cc: Liddie Clark (Monroe)

U.S. EPA, Region III
Director, Air Protection Division
Mail Code 3AP00
1650 Arch Street
Philadelphia, Pa 19103-2029
(Via FedEx – 8001 2756 5686)